DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: 8R-A-1 (PART OF)
DATE:
COUNTY: IREDELL

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: KEJ MARKETING
ADDRESS: PO BOX 1627
MATTHEWS NC 28106

OWNER__ AGENT: ✓ PHONE: (704) 847-6006
APPLICATION DATE: 1/
DATE EVALUATED
PROPOSED FACILITY: 3BR House
PROPERTY SIZE: 0.6662

LOCATION OF SITE: RIVERWALK SECTION I LOT # 19
WATER SUPPLY: On-site Well ✓ Comm. Well___ Public___ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (1) TEXTURE	.1941 (2) STRUCTURE	.1941 (3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	N	0-9	SL	SBK	1:1 / FR			.1942 Wetness Cond. S
	25%	9-33	C	WABK	1:1 / FI			.1943 Depth/.1956 Sapr. S
		33-44	SL	WSBK	1:1 / FR			.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
2	N	0-9	SL	GR	1:1 / VFR			.1942 Wetness Cond. -
	25%	8-32	C	WABK	1:1 / FI			.1943 Depth/.1956 Sapr. -
		32-44	C	WSBK	1:1 / FR			.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
-								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945): S OTHER FACTORS (.1946): NONE SITE CLASSIFICATION (.1948): PS

SYSTEM TYPE: CHAMBERED, PUMPED LONG-TERM ACCEPTANCE RATE(S): 0.3 GPD/FT²

EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: TIM WHITAKER / (704) 866-9540 / RUBY ALLEN

COMMENTS: