DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ *of* ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: David Ason
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: 3 bdr Home PROPOSED DESIGN FLOW (.1949): 330 DATE EVALUATED: _____
LOCATION OF SITE: Rimmer Sect. 3 Lot # 12 PROPERTY SIZE: 1.09 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L/R <5%	0-12	gr / L	vfr sep?	>48	>48	—	—	PS 0.3
		12-21	SBK / CL	vfr sep					
		21-48+	SBK / C	fi sep?					
2	L <5%	0-12	gr / L	vfr sep	>48	>48	—	—	PS 0.3
		12-17	SBK CL	vfr sl					
		17-48+	SBK C	fi sl					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	SOP	LDP-50%
Site LTAR	0.7	0.7

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: JCH
OTHER(S) PRESENT: _____

COMMENTS: No basement plumbing unless pumped up