DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dale Wilson APPLICANT: Tracy Gibson
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 11/1/01
PROPOSED FACILITY: SFR Modular/Manuf PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: .83 Ac
LOCATION OF SITE: ___ PROPERTY RECORDED: Yes
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed Lot # Patriot Pointe

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	7% Linear	0-31	c/cc WSbk	Fr/f SS SP SP					B .3
		31-41	c/cc WSbk	✓ ✓					
		41-48	cl WSbk	Fr SS SP SP					
2	7% Linear	0-16	cl SBk	Fi SS SP SP					B .3
		16-34	cl SBk	Fi SS SP SP					
		34-48	SaCl (Bx)	Fi SS SP SP					
3	Linear Repair	0-7	SCl	SS SP SP					B .25
		7-34	C	Fi SS SP SP					
		34-48	CL WSBk						
4									
					70?				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	8'	8'
System Type(s)	Trad. Conv.	Trad.
Site LTAR	.3	.25

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: ___