ICHD - ENVIRONMENTAL HEALTH DIVISION

Statesville Office (704) 878-5305 | Mooresville Office (704) 660-3625

BB BLDR-2023-14135

PERMIT # OSWP-2022-11509

SEPTIC: IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 3782-73-2873

APPLICANT/OWNER: TONY BREWER/ HYDE HOMES, LLC APPLICANT ADDRESS: 387 WOODBRIDGE ROAD, STATESVILLE, N.C. 28625

SITE ADDRESS: 106 (106) JOHNBOAT COURT, STATESVILLE, N.C. 28677 PHONE: 704-201-9935 ALT. PHONE —

SITE DIRECTIONS: (W) ON 70, (R) ON BLUEWATER, (R) ON PORTSIDE, (L) ON JOHN BOAT, LOT ON (R) SAP CONTROLLED: ☐ YES ☑ NO

SUBDIVISION: RIVER OAKS LANDING SECTION: 1 LOT # 49-50 LOT AREA: 1.449 AC DESIGN FLOW: 360 GPD L.T.A.R. 2275 (0.25) REPAIR

Septic Tank	1000	(gal)	STB 760	Date	7/17/23	☑ New System	☐ Repair	☐ Expansion	System Type: I II (III) IV V VI	☑ Residence	No. Bedrooms 3
Pump Tank	—	(gal)	PT —	Date	—	System Description:		25% REDUCTION		☐ Business	No. Persons 6
Pump Make	—	Model	—	Serial #	—	Repair System Description:		50% REDUCTION		☐ Other	No. Employees —
# Nitrification Fields	1	# Lines	8	Linear Ft	328 FT	Maintenance Agreement Required:		☐ YES	☑ NO	☐ Slab	☐ Crawl Space
Trench Width	36 IN	Trench Bottom Depth(Low side)		17 IN	Gravel Depth	—		☑ GRAVITY	☐ PRESSURE	☑ Basement w/plumbing	☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: INSTALL ON CONTOUR, INSTALL ON 9FT CENTERS UTILIZE SERIAL DISTRIBUTION, DONOT EXCEED A 28IN MAX TRENCH DEPTH, 6IN OF COUNTY APPROVED COVER REQUIRED. SOIL STABILIZATION PLAN REQUIRED, PRE-CONSTRUCTION MEETING REQUIRED. BASEMENT PLUMBING NEEDS TO BE ON GRINDER PUMP

INITIAL SITE SKETCH

SEE ATTACHED SITE PLAN BY: ICHD BRYANT C. WHITE DATED: 1-13-2022

AS BUILT SKETCH

FOR SEPTIC FINAL INSPECTION CALL: 704-664-3703 between 8am-9am the day the inspection is needed. Be sure to speak with an inspector to confirm your time.

Check risers & soil stabilization Tank Lines CW 9/1/23

Installed as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: OS Date: Installed by: Craig Thompson

IMPROVEMENT PERMIT by: Bryant C. White Date: 1-13-2023 OPERATION PERMIT by: Date: 2/14/24

AUTHORIZATION TO CONSTRUCT by: Bryant C. White Date: 1-17-2023 Existing System Inspected by: Date:

FOR SEPTIC FINAL INSPECTION: CALL 704-664-3703 between 8am-9am the day the inspection is needed.

Item	Date	Initials
Drain Lines Checked		
Tanks Checked		
Pressure Manifold or Valve Box Checked		
Pressure Head Set		
Electrical Checked		
Floats Set		
Alarm Checked		
Maintenance Contract Needed? Y / N		
Comments:		


Repairs Only	
	State Code
Failing System Code	
Type of Distribution	G or P
Type of Failure/Malfunction	
Primary Cause of Failure/Malfunction	
Age of System? _____	
Initial or Repair? _____	

104 JOHN BOAT COURT, STATESVILLE, N.C. 28677

3782-73-2873

1 IN = 40 FT

S.T. = SEPTIC TANK



Burfont C. White


1-13-2023

A
SITE PLAN
for

Hyde Homes

SHILOH TOWNSHIP
IREDELL COUNTY, NC
DECEMBER 5, 2022

SU



LEGEND


RCP	REINFORCED CONCRETE PIPE
CMP	CORRUGATED METAL PIPE

LINE	BEARING	DISTAI
L1	S 02°41'04" W	87.00


Acknowledgement of
Plans Submittal ONLY!
OS Date

Bryant C. White Date 1-17-2023


Visit www.DAGmarketplace.com for information on interior and exterior products for your home!



FIRST FLOOR PLAN




TYPICAL PIPE THRU FLOOR



SECTION

SECTION



SEAT DETAIL

SEAT DETAIL

ELECTRICAL LEGEND

SYMBOL	DESCRIPTION
	DUPLEX OUTLET (GROUNDED TYPE)
	WEATHER PROOF DUPLEX OUTLET
	ABOVE COUNTER LOCATION
	FLUSH FLOOR DUPLEX OUTLET, OWNER VERIFY LOCATION
	220 VOLT OUTLET OR CONNECTION
	CEILING MOUNTED LIGHT FIXTURE
	WALL BRACKET MOUNTED LIGHT FIXTURE
	SUSPENDED CEILING MOUNTED LIGHT FIXTURE
	RECESSED DIRECTIONAL CEILING LIGHT FIXTURE
	RECESSED CEILING LIGHT FIXTURE
	RECESSED LIGHT FOR WET AREA
	UNDER CABINET FLUORESCENT LIGHT
	EXTERIOR CURT ASPHALT FLOOD LIGHTS
	CEILING MOUNTED PADDLE FAN W/ LIGHT
	CEILING MOUNTED FAN - EXHAUST
	CEILING MOUNTED FAN AND HEATER
	CEILING MOUNTED FAN AND LIGHT

PLAN NOTES:

VERIFY ALL LOCAL CODES, ENERGY ZONES AND SITE CONDITIONS PRIOR TO CONSTRUCTION. THE OWNER AND BUILDER SHALL BE SOLELY RESPONSIBLE FOR CODE COMPLIANCE

1. REVIEW SELECTED MECHANICAL SYSTEMS WITH OWNER PRIOR TO CONSTRUCTION.

REVIEW SUB-CONTRACTORS LOCATIONS OF THE WATER HEATER AND HVAC UNITS WITH THE OWNER PRIOR TO CONSTRUCTION. ENSURE COMPLIANCE WITH LOCAL BUILDING CODE REQUIREMENTS AND MANUFACTURER REQUIREMENTS.

HVAC EQUIPMENT IN THE ATTIC SPACE SHALL BE ACCESSIBLE BY AN OPENING LARGER THAN THE LARGEST PIECE OF EQUIPMENT (TO ALLOW REMOVAL OF THE EQUIPMENT) AND NO CASE LESS THAN 22"X36"

2. SEE STRUCTURAL DRAWINGS FOR ADDITIONAL INFORMATION.
3. INSULATE AROUND ALL BATHS AND UTILITY ROOM
4. TYPICAL WALL STUDS @ 16" O.C. UNLESS OTHERWISE DIMENSIONED.
5. PROVIDE SMOKE DETECTORS AS REQUIRED BY CODE
6. PROVIDE DOORBELLS, TRANSFORMER AND CHIME

DOOR SCHEDULE

MARK	SIZE	QUAN.	DESCRIPTION
	3'-0" x 6'-8"		EXT. PANEL W/ 2-2" x 10" LITE W/ BEVELED GLASS + 2" ARCH HEAD "TRANSOM" *
2	2'-8" x 6'-8"		EXT. FULL GLASS
3	2'-8" x 6'-8"		EXT. FULL GLASS
4	2'-6" x 6'-8"		EXT. 1-HOUR FIRE-RATED
5	2'-6" x 6'-8"		SCREEN
6	8'-0" x 7'-0"		GARAGE
7	2'-6" x 6'-8"	1	INT.
8	2'-6" x 6'-8"	4	INT.
9	2'-4" x 6'-8"	9	INT.
10	2'-6" x 6'-8"		INT.
	2'-6" x 6'-8"	2	INT.

* SEE ELEVATION FOR TRANSOM

WINDOW SCHEDULE

MARK	SIZE	QUAN.	DESCRIPTION
	2'-6" x 5'-2"		
A	3'-0" x 4'-2"	1	D.H.
	3'-0" x 5'-0"		
B	2'-0" x 4'-2"	1	D.H.
C	12'-0" x 4'-2"	1	D.H.
D	5'-0" x 5'-2"	6	D.H.
E	18'-0" x 5'-0"	1	D.H.
F	3'-0" x 5'-0"	2	D.H.
G	5'-0" x 5'-2"	1	D.H.
H	2'-6" x 5'-0"	2	D.H.
	2'-6" x 5'-2"		
	3'-0" x 5'-2"	1	D.H.
	3'-0" x 5'-2"		
K	2'-6" x 3'-0"	1	FIXED OVAL
L	2'-6" x 5'-2"	2	D.H.
M	3'-0" x 5'-0"		FIXED, ARCH HEAD
N	2'-2 1/2" x 1'-9"		CASEMENT, CENTER FIXED
P	3'-0" x 4'-2"	3	FIXED
Q	6'-0" x 4'-2"		FIXED
R	2'-6" x 4'-6"		D.H.
S	3'-0" x 2'-10"	2	D.H. ARCH HEAD
T	2'-2" x 3'-9"		CASEMENT, FIXED

ALL WINDOWS ARE INSULATED AND WEATHERSTRIPPED.
VERIFY LOCAL CODE EGRESS WINDOW REQUIREMENTS PRIOR TO CONSTRUCTION.
WINDOW MANUFACTURER TO PROVIDE TEMPERED GLASS WHERE REQUIRED BY CODE
VERIFY SPECIFIC MODEL NUMBERS AND SIZES WITH MANUFACTURER BEFORE STARTING CONSTRUCTION.

DONALD A. GARDNER, INC.
P.O. BOX 26178 • GREENVILLE S.C. • 29616
864 • 288 • 7660
www.dongardner.com

RUTHERFORD
DESIGN NO. 1241-A
SHEET 3 OF 9 SHEETS
FIRST FLOOR PLAN

DO NOT SCALE DRAWINGS.
COPYRIGHT ©1/05/06 ALL RIGHTS RESERVED BY DONALD A. GARDNER, INC.
NOT TO BE COPIED OR REPRODUCED WITHOUT WRITTEN PERMISSION

68

52

Visit www.DAGmarketplace.com for information on interior and exterior products for your home!

Acknowledgement Of
Plans Submittal ONLY


Date

Bryant C. White Date 1-17-2023

Visit www.DAGmarketplace.com for information on interior and exterior products for your home!


Copyrighted © Donald A. Gardner Architects, Inc.
and/or Donald A. Gardner, Inc.
REG # 338384 Hyde Homes LLC
These plans may be used for a total of ONE (more) one and the license GRANTED the purchaser, is revocable, for copyright if it is violated. All the federal copyright statutes which provides damages for infringement (set $250 up to $150,000
Permission to construct the building described in this drawings is expressly conditioned on the fact and timely payment of all fees otherwise Donald A. Gardner Architects, Inc. and/or Hyde Homes, LLC
See copyright notice terms on "License to Build" document
This copyrighted architectural plan and specification is protected under the Digital Millennium Copyright act and Donald A. Gardner Architects, Inc. and/or Donald A. Gardner, Inc. reserves to itself all rights to prosecution and recovery of damages, and attorneys' fees for violation of these provisions or removal of this notification is subject to prosecution.
For questions call (985) 384-7660

GABLE PLAN



SECOND FLOOR PLAN

GABLE PLAN



INTERIOR ELEVATIONS

DO NOT SCALE DRAWINGS
COPYRIGHT ©-01/08/08 ALL RIGHTS RESERVED BY DONALD A. GARDNER, INC.
NOT TO BE COPIED OR REPRODUCED WITHOUT WRITTEN PERMISSION

Visit www.DAGmarketplace.com for information on interior and exterior products for your home!

ALL FEDERAL, STATE, AND LOCAL CODES, ORDINANCES, REGULATIONS AND MANUFACTURER'S INSTRUCTIONS ETC. SHALL BE CONSIDERED AS PART OF THE SPECIFICATIONS FOR THIS BUILDING AND SHALL TAKE PRECEDENCE OVER ANYTHING SHOWN. WHERE ALL OR APPLIED RULES SAME ARE AT VARIANCE, THESE PLANS ARE NOT DRAWN FOR ANY PARTICULAR LOCALE. YOU ARE RESPONSIBLE FOR DETERMINING AND ENSURING COMPLIANCE WITH ALL APPLICABLE CODES AND MANUFACTURER'S REQUIREMENTS.

DONALD A. GARDNER, INC.
P.O. BOX 28178 • GREENVILLE S.C. • 29616
864 • 268 • 7660
www.dongardner.com

RUTHERFORD
DESIGN NO.
1941-A
SHEET 4 OF 9
DATE 1984
SECOND FLOOR PLAN

DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH, ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH

Sheet 1 of 2
PROPERTY ID #: 3782-73-2873
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM
(Complete all fields in full)

OWNER: HYDE HOMES, LLC, APPLICATION DATE 12-14-2022
ADDRESS: 387 WOODBRIDGE ROAD, STATESVILLE, N.C. 28625 DATE EVALUATED: 12-30-2022
PROPOSED FACILITY: 3 BR PROPOSED DESIGN FLOW (.1949): 360GPD PROPERTY SIZE: 1.449 AC
LOCATION OF SITE: 104 JOHNBOAT COURT, STATESVILLE, N.C. 28677 PROPERTY RECORDED: YES
WATER SUPPLY: Private ✓Public Well Spring Other
EVALUATION METHOD: Auger Boring ✓Pit Cut TYPE OF WASTEWATER: ✓Sewage Industrial Process Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	FOOT 5%	0-6	FILL	MIXED	FEW SAP INC THRU OUT COLLUVIAL	56"±	NA	NA	PS .3
		6-44	CL, SBK	FR, SS, SP, SEXP					
		44-56	C, ABK	FI, S, P, SEXP					
2	FOOT 3%	0-19	FILL	MIXED	2.5Y 6/2 @ 33"±	62"±	NA	NA	U
		19-62	CL, SBK	FR, SS, SP, SEXP					
3	FOOT 3%	0-24	FILL	MIXED	MIXED COLLUVIAL	36"±	NA	NA	U
		24-36	CL, SBK	FR, SS, SP, SEXP					
4	LINEAR SIDE 20%	0-12	FILL	MIXED	Y/B MOTS 44"± WET	48"±	NA	NA	PS .275
		12-48	LS, P, SEXP	FR, ABK					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25%	50%
Site LTAR	0.275	0.25

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Bryant C. White
OTHER(S) PRESENT:

COMMENTS:

LEGEND

use the following standard abbreviations

LANDSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL .1955 LTAR*	LPP .1957 LTAR*	MINERALOGY/ CONSISTENCE	STRUCTURE
CC (Concave Slope)	I	S (Sand)	1.2 - 0.8	0.6 - 0.4	SEXP (Slightly Expansive)	G (Single Grain)
CV (Convex Slope)		LS (Loamy Sand)			EXP (Expansive)	M (Massive)
D (Drainage Way)						CR (Crumb)
DS (Debris Slump)	II	SL (Sandy Loam)	0.8 - 0.6	0.4 - 0.3		GR (Granular)
FP (Flood Plain)		L (Loam)				SBK (Subangular Blocky)
FS (Foot Slope)						ABK (Angular Blocky)
H (Head Slope)	III	Si (Silt)	0.6 - 0.3	0.3 - 0.15		PL (Platy)
L (Linear Slope)		SiCL (Silty Clay Loam)				PR (Prismatic)
N (Nose Slope)		CL (Clay Loam)				
R (Ridge)		SCL (Sandy Clay Loam)			**MOIST**	**WET**
S (Shoulder Slope)		SiL (Silt Loam)				
T (Terrace)					VFR (Very Friable)	NS (Non-sticky)
	IV	SC (Sandy Clay)	0.4 - 0.1	0.2 - 0.05	FR (Friable)	SS (Slightly Sticky)
		SiC (Silty Clay)			FI (Firm)	S (Sticky)
		C (Clay)			VFI (Very Firm v. Very Sticky)	VS (Very Sticky)
		O (Organic)	None	None	EFI (Extremely Firm)	NP (Non-plastic)
						SP (Slightly Plastic)
						P (Plastic)
						VP (Very Plastic)

*Adjust LTAR due to depth, consistence, structure, soil wetness, landscape, position, wastewater flow and quality.


NOTES

HORIZON DEPTH	In inches below natural soil surface
DEPTH OF FILL	In inches from land surface
RESTRICTIVE HORIZON	Thickness and depth from land surface
SAPROLITE	S(suitable) or U(unsuitable)
SOIL WETNESS	Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
CLASSIFICATION	S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

Evaluation of saprolite shall be by pits.

Long-term Acceptance Rate (LTAR): gal/day/ft^2

Show profile locations and other site features (dimensions, reference or benchmark, and North).



DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH, ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH

Sheet 2 of 2
PROPERTY ID #: 3782-73-2373
COUNTY: IREDELL

SOIL/SITE EVALUATION
***for* ON-SITE WASTEWATER SYSTEM**
(Complete all fields in full)

OWNER: SEE PAGE 1 APPLICATION DATE
ADDRESS: DATE EVALUATED:
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
LOCATION OF SITE: PROPERTY RECORDED:
WATER SUPPLY: Private Public Well Spring Other
EVALUATION METHOD: Auger Boring Pit Cut TYPE OF WASTEWATER: Sewage Industrial Process Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1 5	LINEAR SIDE 25%	0-48	C, ABK	FR, S, P, SEXP	FEW Y/B 42"+ SAP INC THRU OUT	48"+	NA	NA	PS .275
2	LINEAR SIDE 27%	0-50	C, ABK	FR, S, P, SEXP	Y/B NOT 40"+ SAP INC THRU OUT	50"+	NA	NA	PS .25
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT:

COMMENTS:

LEGEND

use the following standard abbreviations

LANDSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL .1955 LTAR*	LPP .1957 LTAR*	MINERALOGY/ CONSISTENCE	STRUCTURE
CC (Concave Slope)	I	S (Sand)	1.2 - 0.8	0.6 - 0.4	SEXP (Slightly Expansive)	G (Single Grain)
CV (Convex Slope)		LS (Loamy Sand)			EXP (Expansive)	M (Massive)
D (Drainage Way)						CR (Crumb)
DS (Debris Slump)	II	SL (Sandy Loam)	0.8 - 0.6	0.4 - 0.3		GR (Granular)
FP (Flood Plain)		L (Loam)				SBK (Subangular Blocky)
FS (Foot Slope)						ABK (Angular Blocky)
H (Head Slope)	III	Si (Silt)	0.6 - 0.3	0.3 - 0.15		PL (Platy)
L (Linear Slope)		SiCL (Silty Clay Loam)				PR (Prismatic)
N (Nose Slope)		CL (Clay Loam)				
R (Ridge)		SCL (Sandy Clay Loam)			**MOIST**	**WET**
S (Shoulder Slope)		SiL (Silt Loam)				
T (Terrace)					VFR (Very Friable)	NS (Non-sticky)
	IV	SC (Sandy Clay)	0.4 - 0.1	0.2 - 0.05	FR (Friable)	SS (Slightly Sticky)
		SiC (Silty Clay)			FI (Firm)	S (Sticky)
		C (Clay)			VFI (Very Firm v. Very Sticky)	VS (Very Sticky)
		O (Organic)	None	None	EFI (Extremely Firm)	NP (Non-plastic)
						SP (Slightly Plastic)
						P (Plastic)
						VP (Very Plastic)

*Adjust LTAR due to depth, consistence, structure, soil wetness, landscape, position, wastewater flow and quality.


NOTES

HORIZON DEPTH	In inches below natural soil surface
DEPTH OF FILL	In inches from land surface
RESTRICTIVE HORIZON	Thickness and depth from land surface
SAPROLITE	S(suitable) or U(unsuitable)
SOIL WETNESS	Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
CLASSIFICATION	S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

Evaluation of saprolite shall be by pits.

Long-term Acceptance Rate (LTAR): gal/day/ft^2

Show profile locations and other site features (dimensions, reference or benchmark, and North).



PERMIT SNAPSHOT REPORT OSWP-2022-11509 FOR IREDELL COUNTY

Permit Type: Environmental Health OSWP
Work Class: EH Septic Improvement Permit
Status: In Progress
Valuation: $0.00
Description: 4 bedroom NEEDS ZONING 3 1/2 bathroom home
New permit

Project:
District: Iredell County
Square Feet: 0.00
Assigned To: White, Bryant

App Date: 12/14/2022
Exp Date: NOT AVAILABLE
Completed: NOT COMPLETED
Approval Expire Date:

Parcel: 3782732873.000 Main

Address: 104 Johnboat Ct Main
Statesville, NC 28677

Zone: RA(Residential Agricultural District)

Property Owner
TONY BREWER
PO BOX 5041
STATESVILLE, NC 28687

Project Contact
Hyde Homes, LLC
387 Woodbridge Rd 129
WHISPER PINE RD.
Statesville, NC 28625
Business: (704) 201-9935

Applicant/Authorized Agent
Hyde Homes, LLC
387 Woodbridge Rd 129
WHISPER PINE RD.
Statesville, NC 28625
Business: (704) 201-9935

Permit Custom Fields

How is your site plan being submitted	Survey Plat	Does the site contain any jurisdictional wetlands	No	Non-domestic Sewage Generated	No
Other Public Agency	No	All proposed structure dimensions	house 69'10" x 51' Building 30 x 35 Pool 20x40	What are the proposed structures	Accessory Building, New Single Family Residence
If other Addition/Structure, please explain	2901 heated sq foot home with proposed garage/storage building on propoerty	Maximum Number of Bedrooms	4	Number of Occupants	2
Foundation Type	Basement with Plumbing	Water Supply	Other Public Water	Desired Septic System Type	Conventional (most common)
If other septic system type, please explain		Lot Acreage	1.243	Front Setback	35
Back Setback	50	Left Setback	15	Right Setback	15
Zoning Permit Issued Date	Dec 15 2022 12:00AM	Zoning Permit Expiration Date	Jun 13 2023 12:00AM	Is the structure or development in the floodplain	Yes
Is the property in a local historic district?	No	Is the property located downtown?	No	Zoning Notes/Addendums	Lake Lots: Must meet both the 50-foot setback from the 760' contour line and the 35-foot setback from the rear property line for any structure.
Additional Unique Setbacks Apply	No	Watershed	WSIV CA CATAWBA/LAKE NORMAN		

Attachment File Name	Added On	Added By	Attachment Group	Notes
Signature_Joseph_Hyde_12/14/2022.jpg	12/14/2022 11:41	Hyde, Joseph		Uploaded via CSS
JOHN BOAT SITE PLAN PLS With POOL_v1.pdf	12/15/2022 14:37	Nebel, Barbara	Available Online	Site Plan
Johnboat septic permit 2022-12-08_123107_v1.pdf	12/15/2022 14:37	Nebel, Barbara	Available Online	Authorize to Act as Agent

Inspection Number	Status	Inspection Type	Request Date	Scheduled Start Date	Scheduled End Date	Actual Start Date	Actual End Date
2022-46853	Passed - Permit	OSWP Septic/Well Preliminary Site Visit	12/20/2022			12/20/2022 16:22	12/20/2022 16:22


Inspectors: Kobuck, Teanna (Primary)

Checklist Item	Description	Passed	Comments
General Comments	Checklist item used to track general comments, not specific to any other checklist item	No	

PERMIT SNAPSHOT REPORT (OSWP-2022-11509)

Invoice No.	Fee		Fee Amount	Amount Paid
INV-00006461	New Gravity System		$500.00	$500.00
		Total for Invoice INV-00006461	$500.00	$500.00
INV-00006464	Iredell Zoning Permit Fee		$75.00	$75.00
	Iredell Zoning Tech Fee		$2.25	$2.25
		Total for Invoice INV-00006464	$77.25	$77.25
		Grand Total for Permit	**$577.25**	**$577.25**

Workflow Step / Action Name	Action Type	Start Date	End Date
Application Completeness Check v.1		12/15/2022 14:38	12/15/2022 14:38
Confirm application complete v.1	Generic Action		12/15/2022 14:38
Fees v.1		12/15/2022 14:38	12/16/2022 11:10
Issue Invoice v.1	Generic Action		12/15/2022 14:38
Fees Paid v.1	Generic Action		12/16/2022 11:10
Zoning Review v.1		12/15/2022 14:38	12/16/2022 11:21
Iredell County Zoning Approval v.1	Task	12/15/2022 14:38	12/16/2022 11:21
Issue Invoice v.1	Generic Action		12/15/2022 14:55
Fees Paid v.1	Generic Action		12/16/2022 11:10
Lot Readiness Verification v.1		12/20/2022 16:22	
OSWP Septic Preliminary Site Visit v.1	Inspection	12/20/2022 16:22	12/20/2022 16:23
OSWP Site Evaluation v.1	Inspection		
Issue Improvement Permit v.1			
Issue Invoice v.1	Generic Action		
Fees Paid v.1	Generic Action		
Issue Permit v.1	Generic Action		
Permit Completion Process v.1			
Authorization to Construct Permit v.1	Create Sub Permit		
Issue Authorization to Construct v.1	Generic Action		


3782-74-3029
252
51
100
3782-73-3919
100
100
261
Pit3
Pit4
Pit6
Pit1
Pit5
44
37
37
39
36
35
32
46
46
42
42
38
38
38
38
104
116
50
100
Pit2
3782-73-2873
ADD SOFT BUFFER
106
116
49
54
79
35
196
3782-73-4633
114
48