IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Peter Krutsch DATE 12/28/77 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION I-40 to Sharon School Rd. T.R. – T.L. at School House – T.L. on Lookout Dam Rd. T.R. in drive just beyond Gantt Boat Landing S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 3. acres

Character & Porosity of Soil Prof Suitable
Percolation Rate _____
Topography Slope to Lake
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Dillard & Foote
Davie County

IMPROVEMENTS PERMIT BY _____

COMMENTS: Surface water to be diverted away from septic Tank & lines. Lines to have 18"-24" Cover on low side.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 12/28/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold