~~39454~~
37753

11757.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR ROGER DALE POPE DATE 7-25-96 PERMIT NO. PT. OF 96-A-3.

PHONE: Business _____ Home _____

LOCATION: Hwy-T.R. to Shiloh Rd.-T.L. on 1st Left past Donald Cragnes ½ mi. past Bethel Church L.T.R. on private drive just before Jesse Inspectors Rd. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. Jesse Sifford

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Prev. Suitable.
Percolation Rate 2 Gal./Sq. Ft.
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations None Observed.

Lot Area 2.0 Acres.


_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Linear Ft. 300
Depth of Stone in Lines 24"
Water Supply: Individual (✓)
Public ( )

Installed by Taylorsville Mfg. Eddie Kolb

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____



Plot of System

IMPROVEMENTS PERMIT BY: Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY: Steve Brown DATE 7-25-96.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold