DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Ronald Miller APPLICANT: _____
ADDRESS: 232 Laurkyn Lm Rd APPLICATION DATE: _____ DATE EVALUATED: 10/8
PROPOSED FACILITY: 3BR MH/Crawl Space PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.0
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	2%	0-10	c	fi sp SEH					VS
		10-24	cl	fr ss sp SEH					
		24-	Rock						
2	7%	0-14	sc/sc	Fr SS sp SEH					PS .3
		14-48	cl Sbk	Sp SEH					
3	6%	0-8	scl	fr					PS .3
		8-40	c	fi sp SEH					
		40-48	cl Smpl	fi SS sp SEH					
4	6%	0-11	scl	fr SS sp SEH					PS .3
		11-36	c	fi sp SEH					
		36-48	cl Smpl	Fifr SS sp SEH					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity 25% Red	Gravity 50% Reduction
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____