IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Beans DATE 7/6/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W., T.R. on Shanon School Rd., T.L. on Rd # 1500, trailer on left just past Bethel Methodist Church S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 6 acres

Character & Porosity of Soil Prov. Suitable
Percolation Rate _____
Topography Slight
Depth to Water Table Low
Rock or other impervious formations none observed



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16
Water Supply: Individual (✓)
Public ( )

Installed by Hanks Looky

IMPROVEMENTS PERMIT BY _____

COMMENTS: Well to be upfront of Mobile Home

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 7/6/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold