DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: James Setzer APPLICANT: Joseph Setzer
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 21.42
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	7% Linear	0-2	scl sblk	fr ss sp SEXP	39" BRN/Yellow mottles				PS .30
		2-24	cl m sblk	fi ss sp SEXP					
		24-36	c Ablk	fi ss sp SEXP					
		36-49	c/cl sblk	fi ss sp SEXP					
2	7% Linear	0-18	sl g	fr NS NP NEXP	44" Blk mottles				PS .35
		18-24	scl sblk	fi/fr ss sp SEXP					
		24-49	cl/c sblk	fi ss sp SEXP					
3	8% Linear Repair	0-3	sl g	fr NS NP NEXP					PS .25
		3-20	cl sblk	fi/fr ss sp SEXP					
		20-49	c Ablk	fi sp SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Pump, Conventional	Pump Conventional
Site LTAR	.30	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____