3130

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Sipe DATE 6-6-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I 40 W To Sharon School Rd T.R. Green House on L Just before Richard Sipe Ser Sta S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No ( ) | |
| Auto. Dishwasher | Yes ( ) | No ( ) | |
| Auto. Wash. Machine | Yes ( ) | No ( ) | |
| Site Suitable | Yes ( ) | No ( ) | |

Lot Area _____

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table Repair
Rock or other impervious formations _____




Plot of System

Size of Tank Old Tank Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 500 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by N. Iredell Septic Tank Co

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Have basement drain diverted away from lines. Tank pumped out and Checked for Tee.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6-10-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold