IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Howard Setzer DATE 10-24-73 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION I-40 To Sharon School Rd # 1502 T.R. Trailer on L. Across from I 40 Shell Sta. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes (✓) No ( )
Lot Area Acreage

Character & Porosity of Soil Clay
Percolation Rate Per Perk Test
Topography Slightly Sloping Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 400
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harlu Lackey

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Location of Trailer and system changed from original Layout. Tank + first 50' of line are deep! Original layout would have been better system.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11-7-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold