38118

IREDELL COUNTY HEALTH DEPARTMENT

1970. (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 89-A-31
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR THOMAS THOMPSON DATE 10-1-90 PERMIT NO. 89-A-21C.

PHONE: Business _____ Home _____

LOCATION Iron Station Rt. out on Troy-Goose Creek 1.25 mi. past Union Supermarket, T. L. on Jim Clark Rd. (Listed) Check Plat for Lot & Sec. S.R. No. 2410

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 60 acres

Character & Porosity of Soil Sandy Loam Suitable
Percolation Rate 2 - 60 min/in
Topography 2 - 6%
Depth to Water Table 10'+
Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Lineal Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Dennis Sullivan

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Well 65' from S.T. system.

CERTIFICATE OF COMPLETION BY Steve Brown

EXISTING SYSTEM CHECKED BY: _____ DATE 10-1-90

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold