IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Billy E. Pope DATE 8-13-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-40 W - T.R. on Sharon School Rd. T.L. at School T-L. at M. J. Morrows Store T.R. on 1530. Go approx ½ M. Trailer on L S. R. No. 1530

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3½ Acres


Character & Porosity of Soil Red Clay Loam

Percolation Rate _____

Topography Slope to back

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Bill + Ray Bumgarner

IMPROVEMENTS PERMIT BY _____

COMMENTS: Concrete Tile Lines –

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8-13-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold