DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: Johnston

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Augustin Rogue APPLICANT:
ADDRESS: 717 Shorewalk Rd Stanley NC APPLICATION DATE: 2-23-00 DATE EVALUATED: 3-28-2000
PROPOSED FACILITY: 3Bd Rm MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 2 Ac
LOCATION OF SITE: Sharon School Rd Nth Duncan Club ~7 mile on left PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ	PROFILE CLASS & LTAR
1	L 8-10%	0-34	SAB C	FR SS					PS .3 24-30"
		34-36+	C/SAP	VFR					
		36+	SAP/						
2	L 12-15%	0-34	SAB C	FR SS					PS .3
		34-40	SAB C/	VFR					
		40-52	C/	FR-VFR					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	✓	✓
System Type(s)	Gravity Conv.	
Site LTAR	.3	.3 +

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. Coffey
OTHER(S) PRESENT: