IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Steve Davidson DATE 7-29-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Sharon School Rd. House on L. approx 1 mile above M. J. Monroe's Store. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 1 3/4 Acres

Character & Porosity of Soil Red Clay
Percolation Rate _____
Topography Slope to back of lot
Depth to Water Table Low
Rock or other impervious formations None



Plot of System PD # 15-29

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: All surface water possible should be diverted away from Tank & Lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 7-29-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold