DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 3784455849
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Sara Waugh
ADDRESS: 1151 Sharon School Rd
PROPOSED FACILITY: 4BR
PROPOSED DESIGN FLOW (.1949): 480
LOCATION OF SITE: 1151 Sharon School Rd.
WATER SUPPLY: • Private • X Public • Well • Spring • Other
EVALUATION METHOD: • X Auger Boring • Pit • Cut
TYPE OF WASTEWATER: X Sewage • Industrial Process • Mixed

APPLICATION DATE: 3/20/12
DATE EVALUATED: 4-12-12
PROPERTY SIZE: 16.2
PROPERTY RECORDED: n/a yes

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 12	0-24	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		24-48	CL SBK	SS SP					
2	LS 12	0-23	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		23-48	CL SBK	SS SP					
3	LS 10	0-17	C SBK	SS SP	n/a	48"	n/a	n/a	3 PS
		17-48	CL SBK	SS SP					
4	LS 10	0-19	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		19-48	CL SBK	SS SP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	.3	.3

OTHER FACTORS (.1946): none
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: James Stewart
OTHER(S) PRESENT: Alford, Waugh

COMMENTS: