# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

01496

OWNER OR CONTRACTOR FRED CHAPMAN DATE 7-25-84 PERMIT NO.

PHONE: Business Home

LOCATION I'40 West, T.R. on Shiloh School Rd. - 3 miles on Left. S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 acre

Character & Porosity of Soil Prov. Suitable


Percolation Rate 4 gal/sq ft.

Topography 2 Ca's +

Depth to Water Table 18" +

Rock or other impervious formations none observed.

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement




Plot of System

Size of Tank 1500 Gals.

Nitrification Field: 3

No. of Lines

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Do not drive or park over any part of S.T. system.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-25-84

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold