DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT (1)

PROPERTY I.D.#: _____ SHEET ___ OF ___
DATE: 4-10-95
COUNTY: Iredell

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Sun-wood Bldrs
ADDRESS: _____
OWNER ___ AGENT: ___ PHONE: _____
APPLICATION DATE: _____ DATE EVALUATED 4-10-95
PROPOSED FACILITY: 4 Bedroom House
PROPERTY SIZE: _____

LOCATION OF SITE: Sharon school Rd
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (1) TEXTURE	(2) STRUCTURE	(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1		0-4"	cl	gr	1:1 / fr			.1942 Wetness Cond. - S
		4"-30"	c	sbk	1:1 / fi			.1943 Depth/.1956 Sapr. - NA
		30"-37"	c/weathered rock	wsbk/m	1:1 / fi			.1944 Restrictive Hori. - 37" P.S.
		37"-48"	weathered rock	m	vfi			.1948 Profile Class. - PS.
								Profile LTAR - .3
2		0-2"	cl	gr	1:1 / fr			.1942 Wetness Cond. - S
		2"-40"	c	sbk	1:1 / fi			.1943 Depth/.1956 Sapr. - NA
		40"-48"	c/sap.	wsbk/m	1:1 / fi			.1944 Restrictive Hori. - NA
								.1948 Profile Class. - PS
								Profile LTAR - .3
3		0-3"	cl	gr	1:1 / fr			.1942 Wetness Cond. - S
		3"-36"	c	sbk	1:1 / fi			.1943 Depth/.1956 Sapr. - 40" P.S.
		36"-40"	c/sap.	wsbk/m	1:1 / fr			.1944 Restrictive Hori. - NA
		40"-48"	sap.	m	fr			.1948 Profile Class. - PS
								Profile LTAR - .3
4		0-2"	cl	gr	1:1 / fr			.1942 Wetness Cond. - S
		2"-48"	c	sbk	1:1 / fi			.1943 Depth/.1956 Sapr. - NA
								.1944 Restrictive Hori. - NA
								.1948 Profile Class. - PS
								Profile LTAR - .3

AVAILABLE SPACE (.1945) 5 OTHER FACTORS (.1946) _____ SITE CLASSIFICATION (.1948) P.S
SYSTEM TYPE conventional, gravity fed LONG-TERM ACCEPTANCE RATE(S) .3gpd/ft²
EVALUATED BY: Michael J Dunn OTHER(S) PRESENT: Perry Jenkins.
COMMENTS: _____

001925