DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

133516
3784-61-0634

OWNER: CAROL DELLINGER
ADDRESS: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): 420
LOCATION OF SITE: BEHIND 2343

APPLICATION DATE ___
DATE EVALUATED: ___
PROPERTY SIZE: ___
PROPERTY RECORDED: ___

WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
2	3 SAME	0-6	scl wkgr	f nsnpnsp					PS
	10%	6-48	lms cdsbk	f sssps					
1	L		L7 sky Hue 5Y 5/1	c 50%	36-48" WLM	74" Com	bc	50"	3
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	CONV 75	SAME
Site LTAR	13	13

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: C. COOL
OTHER(S) PRESENT: ~~CHUCK~~ JAMES SUTTON

COMMENTS: OWNER REQUEST 3540 GPD