IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 143620 PIN# 3784 90 2320 DATE 3-11-08

OWNER OR APPLICANT HENDRICK BUILDERS PHONE: Business 704-902-0574 Home 872-5095

ADDRESS 546 New Sterling Rd Stanley NC 28164

LOCATION 40 WEST @ SHARON SCHOOL @ FALLOW LEAF ON LEFT

SUBDIVISION SHARON TRACE BLOCK / SECTION 2 LOT 37 LOT AREA 1506 SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. 1.3

Septic Tank: 1000 Gallons: STB 1012 Date 4-10-07

Pump Tank: _____ Gallons: PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 672 Linear Feet 300'

No Lines 5 Trench Width 36" Max Trench Bottom Depth 36" ~~24"~~

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: CONVENTIONAL 25% RESERVE

Repair System Description: LC 50% REPAIR AREA

Maintenance Agreement Required: ☐ Yes ☐ No

Gravel Depth N/A ☐ Gravity ☐ Pressure

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons 6 No. Employees ____

Water Supply: ☐ Individual ☒ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: (1) INSTALL DRAIN LINES AT 36" DEEP DUE TO THE HUMPS & BUMPS IN THE CONTOURS. (2) HOUSE & SYSTEM STAKED OUT COMPLETELY. WENT OVER ENTIRE PERMIT W/ OWNER

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGNED BY LORNE COOK, P.S.

Comments:/Conditions: BUILDER (3) BACK OF LOT CAN NOT BE GRADED. (4) KEEP STUBOUT HIGH ENOUGH SO GRAVITY FALL CAN BE ACHIEVED AT DRAIN. (5) KEEP HOUSE OUT OF GROUND & BACKFILL FOR POSITIVE

AS BUILT SKETCH ORIGINAL LINES

TUFFLINE FILL MATERIAL

SYSTEM 10' OFF CORNER P/L & SUPPLY LINES RAN EXACTLY ½" FALL PER FOOT.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Hendrick Builders date _____

Improvement Permit by: [signature] date 3-11-08

Authorization to Construct by: [signature] date 3-11-08

Installed by: CRAIG Thompson Grading

Operation Permit by: [signature] date 5-19-08

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

143 620
3784 90 2322

