DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Martin Hendricks
ADDRESS: _____
PROPOSED FACILITY: 3bR. House
LOCATION OF SITE: Lot #35 - Sharon Ivie

APPLICATION DATE _____
DATE EVALUATED: 19 Feb 07
PROPOSED DESIGN FLOW (.1949): 360gpd
PROPERTY SIZE: 0.5A.
PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 7%	0-6	gr / LS	VFR / Sap	>48	>48			PS 0.3
		6-48+	SBK / LS	Fr / Sap					
2	L 7%	0-7	gr / LS	VFR / Sap	>48	>48			PS 0.3
		7-48+	SBK / SCL	Fr / Sap					
3	L 7%	0-6	SBK / SCL	Fr / Sap	>48	40"			PS 0.3
		6-40	SBK / C	Fr / Sap					
		40+	Sap						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: TCH
OTHER(S) PRESENT: _____

COMMENTS: _____