HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Dewey Lester OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 1-25-95
PROPOSED FACILITY: 3 Bedroom SW MH
PROPERTY SIZE:
LOCATION OF SITE: Island Ford Rd.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	25% L	0-6"	l	gr	1:1	.1942 WETNES CONDITION - S
		6"-48"	c	wsbk	ss 1:1	.1943/.1956 SAPROLITE - NA
						.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .33
2	25% L	0-5"	l	gr	1:1	.1942 WETNES CONDITION - S
		5"-48"	c	wsbk	ss 1:1	.1943/.1956 SAPROLITE - NA
						.1944 RESTRICTIVE HORIZON - NA
						1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .33
3	25% L	0-5"	l	gr	1:1	.1942 WETNESS CONDITION - S
		5"-48"	c	wsbk	ss 1:1	.1943/.1956 SAPROLITE - NA
						.1944 RESTRICTIVE HORIZON - NA
						1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .33
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .33 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE conventional, gravity fed.
EVALUATED BY: Michael R. Dennis OTHER(S) PRESENT: Dewey Lester
COMMENTS:

DRAFT