DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

1 of 2

OWNER: Charles Payne APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: 3BRM MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 4 Acres
LOCATION OF SITE: _____ PROPERTY RECORDED: ADU
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	Linear 5%	0-12	SCL		14" YB Red mottles				US
		12-	SCL		20" Chroma 2				
2	Linear 4%	0-11	SCL		13" mottles 18" chroma 2				US
		11-24	SCL w clay						
3		0-3	SCL						PS .35
		3-17	SL						
		17-32	SCL/clay						
		32-48	Sap						
4	Linear 6%	0-5	SCL						PS .25
		5-16	SCL		16" YB/Red mottles 24" YB/Red mottles 36" Chroma 2				
		16-28	SC						
		28-48	C	sap					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Lehman
OTHER(S) PRESENT: Charles Payne