IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bryant Waugh DATE 9-27-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old Mt. Rd. Past Bradford & Rd. T.L. on New Sterling Ch. Rd #1526 T.R. on #1527 T.R. on 1532. Cross Creek. Go to Top of Hill. T.L. Red Drive

SUBDIVISION NAME Inside back off of Road. LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 9 Acreage

Character & Porosity of Soil Red Clay
Percolation Rate _____
Topography Slope to back of lot Low
Depth to Water Table _____
Rock or other impervious formations [redacted] soft rock hit near end of ditch



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harlo Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: To build home site.

CERTIFICATE OF COMPLETION BY C. A. Stevenson DATE 9/27/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold