Dave Pritchard
Bldr.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Waugh DATE 2/3/77 PERMIT NO.

PHONE: Business Home

LOCATION Old Mountain Rd. East Bradford & Rd. T.R. on New Sterling Ch. Rd #1526 - T.R. on Rd. 1527 T.R. on 1532. Go ½ mile House on L.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO. S. R. No.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area Acreage

Character & Porosity of Soil Red Clay
Percolation Rate
Topography Slope to back of Lot
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY

COMMENTS: Downspouts & Surface Water should be diverted away from Tank & lines

CERTIFICATE OF COMPLETION BY E. H. Stevenson DATE 2/3/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold