DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: SHARON IRON SLOAN APPLICANT: ___
ADDRESS: 2329 OLD MTRD STATESVILLE NC APPLICATION DATE: 7-6-99 DATE EVALUATED: ___
PROPOSED FACILITY: 3BdRm DW PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .72
LOCATION OF SITE: OLD MTRD (L) COUNTY LINE (L) JORDAN CUST (L) LOT 12 VICTORIA LANDING 2 PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 2%	0-20	SBK C	FR SS SP SEAP					PS .3+
		20-46	SBK C	FR SEAP					
		46-50	SBK/GR C/SAP	VFR					
2									
3	L 5%	0-24	SBK C	FR SS SP SSP					PS .3
		24-41	SBK C	VFR SS					
		41-52	SBK/GR C/SAP	VFR					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 sqft	1200 sqft
System Type(s)	II A Conv Trench	II A Conv Trench
Site LTAR	3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [illegible]
OTHER(S) PRESENT: OWNER