DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: Franklin

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Wendell Turcott APPLICANT:
ADDRESS: 2320 Huckleberry Ridge Rd Middlesex APPLICATION DATE: 9.23.99 DATE EVALUATED: Oct 12 99
PROPOSED FACILITY: 4 Bdrm DW PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: 41052 sqft
LOCATION OF SITE: Victorias Landing Lot 24-25 N Old NC 39 (1) Huckleberry (2) Indian Cust on Right PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 2 3%	0-18	SAB C	FR SS SP SCSP					PS .3
		18-52	SAB W C w/mica	FR SS SCSP					
2	L 2 3%	0-26	SAB C	FR SS SP SCSP					PS .3
		26-48	SAB W C/SAP Fine Sand	FR SS SCSP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1600 sqft	5th e
System Type(s)	25% Red. Trench	Same
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Jo Cotton
OTHER(S) PRESENT: Owner