DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jerry Hall APPLICANT: Fleetwood of Statesville
ADDRESS: 1270 Nashville Hwy Statesville APPLICATION DATE: 5/13/02 DATE EVALUATED: 7/22/02
PROPOSED FACILITY: 36RMH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.76 Ac
LOCATION OF SITE: _____ PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	11%	0-40	SL w/ rock	FrFi SS, SP					PS .30
		60	Rock						
2	10%	0-42	SL w/ rock	Fr SS, SP					PS .30
		42	Rock						
3	11%	0-40	SL w/ rock	Fr SS, SP					PS .30
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	95	0
System Type(s)	Trench, Con	Pump & Dose
Site LTAR	.30	.30

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: [signature]
OTHER(S) PRESENT: _____