IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mike Walker DATE 8/21/84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old Mountain Road, Lf on Pressley Farm / 3/4 mile on Rt

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area .5 acre

Character & Porosity of Soil Cecil clay
Percolation Rate 6 gal/ft²/day
Topography G-10%
Depth to Water Table 10' +
Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement




Plot of System PRESSLEY FARM

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 10' +
Water Supply: Individual (✓)
Public ( )

Installed by Harley Lackey Const.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: 10' Stone in trench. Permit expired. Schedule 40 4" PVC Not installed between tank & D Box at time of inspection

CERTIFICATE OF COMPLETION BY Billy H Shuler RS DATE 8/21/84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold