IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert L. Forsythe DATE 4-12-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old Mountain Rd. Approx 1 Mile above Bedfords X Roads T.L. on Rd #1534 (Sandy Farm Rd) Trailer on R. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


Harry Walker Farm

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	No Perk Test
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Slope Low
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	None
			Rock or other impervious formations	

Lot Area Acreage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 630 Linear Ft. 252

Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Alexander Septic Tank Co.

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: No Well on Property at time of Inspection. Well to be at least 50' away from Tank + lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4-12-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold