DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Clyde Holt Est. APPLICANT: Jim Combs
ADDRESS: _____ APPLICATION DATE: 4/20/01 DATE EVALUATED: 4/26
PROPOSED FACILITY: 3BR mH Class PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.25
LOCATION OF SITE: _____ PROPERTY RECORDED: Y
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Cain Road Eaton Lot #21

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	6% O Linear	0-34	cl vfsk	Fi sp SExp					PS .25
		34-48	cl fi sk	VFi sp SExp					
2	5% Linear	0-9	scl	Fr SExp					PS .25
		9-14	cl	Fi SExp					
		14-48	cl	Fi SExp					
3	5% O Linear	0-24	Scl	fr SExp	30" Yellowish Brn Mottles				PS .25
		24-36	~~cl~~ cl	Fi SExp					
		36-49	cl	Fi SExp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv. 25% Reduction	Conv. 50% Reduction
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____