)N-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

)WNER: CLYDE HALL APPLICANT: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____

ROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____

OCATION OF SITE: lot 22 PROPERTY RECORDED: _____

/ATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

.VALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut

YPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-6	BSCL GR	FRE SSSP					PS .3
		6-28	RC SBK	FI SP					
		28-48	RCL WSBK	FRE SSSP	Yellow Motels @ 42"				
2		0-4	BSCL GR	FRE SSSP					PS .3
		4-30	RC SBK	FRE SSSP					
		30-48	LCL WSBK	FRE SSSP	Yellow Motels @ 42-48"				
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
.vailable Space (.1945)		
ystem Type(s)		
ite LTAR		

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____

OTHER(S) PRESENT: _____