IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR THEODORE COWAN DATE 7-7-88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 14-77 West Brown Island Rd. - Double Wide on left
Right on Hill Side Bldg. on R.

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 13E SECTION OR BLOCK NO. _____


Double Wide

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3	No. Bathrooms 1.5	Character & Porosity of Soil	Prev. Suitable.
Garbage Disposal Unit	Yes ( ) No ( )	Percolation Rate	30 Min./in.
Auto. Dishwasher	Yes (✓) No ( )	Topography	2-Left Front
Auto. Wash. Machine	Yes (✓) No ( )	Depth to Water Table	12'+
Site Suitable	Yes (✓) No ( )	Rock or other impervious formations	none observed.

Lot Area Ample

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Dennis Hollister

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-7-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

JAN. 12, 1989 3:50