IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Allen Stephens DATE Sept. 8, 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I 40 W to Sharon School Rd., T.L., T.L. on #SR 1504, house on right

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 3 acres


Character & Porosity of Soil Red clay

Percolation Rate _____

Topography slight slope Low

Depth to Water Table _____

Rock or other impervious formations none observed



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft 625 Linear Ft. 250

Depth of Stone in Lines _____

Water Supply: Individual (✓)

Public ( )

Installed by Omar Alexander

IMPROVEMENTS PERMIT BY _____

COMMENTS: Well to be more than 50 ft. from septic tank line

CERTIFICATE OF COMPLETION BY Charles B. Brindle + Andrew E. Causey DATE Sept. 8, 1976

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold