DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 3792-38-6161
COUNTY: [illegible]

SOIL/SITE EVALUATION *for* ON-SITE WASTEWATER SYSTEM

OWNER: Robert Sharpe APPLICANT: Same
ADDRESS: 160 Sharon Sch Rd APPLICATION DATE: _____ DATE EVALUATED: 8-13-9
PROPOSED FACILITY: 3BR D/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: Acreage
LOCATION OF SITE: 160 Sharon Sch Rd PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	L 8%	0-20	SBK S	FI SEAP					PS 0.3
		20-30	GRAVELLY SBK SC	FI SEAP					
		30-48	SBK CL	FR SEAP					
2	L 6%	0-22	SBK C	FI SEAP					PS 0.3
		22-30	GRAVELLY SBK SC	FI SEAP					
		30-48	SBK CL	FR SEAP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Availbble Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): None
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. Hedrick
OTHER(S) PRESENT: Robert Sharpe