IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR CHARLES SHARPE DATE 4-21-83 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-40 west, T.L. on State rd. Bucknum Rd., then T.L. on first dirt rd., T.L. at Littlered Rdg. - go straight on Left


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1-2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Gilday Loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min/in.	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	12+	
Lot Area Ample			Rock or other impervious formations	none observed.	

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by AAA Enterprises

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Pipe off downspouts from gutters across drainfield.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-27-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold