DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Reta Hoover
ADDRESS: 133 Watts Meadow DR
PROPOSED FACILITY: 3Bdrm House
LOCATION OF SITE: ___
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

APPLICANT: ___
APPLICATION DATE: 9 22.98 DATE EVALUATED: 7-21-99
PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 2.3Ac
PROPERTY RECORDED: ___

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 10-12%	0 12	SBK CL	FR					PS .3
		12 48	SBK C^RL	FR					
2	L 12-15%	0 12	SBK CL	FR					PS .3
		12 48	SBK C	F					
3	L 15-15%	0 16	SBK CL	VFR-FR					PS .3
		16 48	SBK C^RL	FR					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	100% Sfr	None
System Type(s)	Conv Chamber	Same
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: C. Potter
OTHER(S) PRESENT: Owner