HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

①

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: Tuscola

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Calvin Upright OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 4-18-95
PROPOSED FACILITY: 3 Bedroom MH (SW)
PROPERTY SIZE: ± 3.0 acres
LOCATION OF SITE: Eufola Rd.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	1941 (a)(2) STRUCTURE	1941 (a)(3) MINEROLOGY		
1	6-8% L	0-36"	Sap/weathered Rock			.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	- U
						PROFILE LTAR	-
2	6-8% L	0-36"	Sap/weathered Rock			.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	- U
						PROFILE LTAR	-
3	6-8% L	0-10"	C			.1942 WETNESS CONDITION	-
		10"-36"	Sap/weathered Rock			.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	- U
						PROFILE LTAR	-
4	6-8% L	0-24"	Sap/weathered Rock			.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	- U
						PROFILE LTAR	-
5	6-8% L	0-36"	Sap/weathered Rock/c		2:1 clay	.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	- U
						PROFILE LTAR	-

AVAILABLE SPACE (.1945): SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE:
OTHER FACTORS(.1946): SYSTEM TYPE:
EVALUATED BY: Michael Q Dennis OTHER(S) PRESENT: Calvin Upright, Treasa Crawford
COMMENTS: re-evaluate when area cleared off, property lines staked, and flagged.

DRAFT

002134