HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

(2)

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: Judell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Calvin Upright OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 4-25-95
PROPOSED FACILITY: 3 Bedroom SW MH
PROPERTY SIZE: ± 3 acres
LOCATION OF SITE: Eufola Rd
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	4-6% L	0-3"	cl	gr	1:1 / f_v	.1942 WETNESS CONDITION	S
		3"-38"	c	sbk	1:1 / f_i	.1943/.1956 SAPROLITE	42" P.S
		38"-42"	c/sap	wsbk/m	1:1 / f_i	.1944 RESTRICTIVE HORIZON	NA
		42"-48"	sap	m	1:1 / f_v	.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
2	4-6% L	0-4"	cl	gr	1:1 / f_r	.1942 WETNES CONDITION	S
		4"-30"	c	sbk	1:1 / f_i	.1943/.1956 SAPROLITE	37" P.S
		30"-37"	c/sap	wsbk/m	1:1 / f_i	.1944 RESTRICTIVE HORIZON	NA
		37"-48"	sap	m	1:1 / f_v	.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
3	4-6% L	0-3"	cl	sbk	1:1 / f_r	.1942 WETNESS CONDITION	S
		3"-40"	c rela mottling	Abk	1:1 / f_i	.1943/.1956 SAPROLITE	NA
		40"-96"	c/sap	wsbk/m	1:1 / f_i	.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.3
4	4-6% L	0-4"	cl	sbk	1:1 / f_r	.1942 WETNESS CONDITION	S
		4"-30"	c rela mottling	Abk	1:1 / f_i	.1943/.1956 SAPROLITE	NA
		30"-48"	c/sap.	wsbk/m	1:1 / f_i	.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.3
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .31 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE pump to conventional
EVALUATED BY: Michael Davis OTHER(S) PRESENT: Calvin Upright
COMMENTS:

DRAFT

0 0 2 1 3 5