IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sam Watts DATE 11/1/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70W. T.L. at New Bethany Baptist Church on Rd#1333. White Cinder Block House on Rt. S. R. No. 1333

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area acreage

Character & Porosity of Soil Prof Suitable
Percolation Rate _____
Topography Slight Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Omar Alexander
adding bathroom to existing House

IMPROVEMENTS PERMIT BY _____

COMMENTS: All surface water possible to be diverted away from Tank + lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11/1/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold