09654

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR BRENT COOK DATE 4-4-89 PERMIT NO. 13D

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W-T.L. on 1st driveway past Stewart's Store - Double Wide back off rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

Dewitt Sands

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area Ample

Character & Porosity of Soil Appears Suitable


Percolation Rate 2 Gal. Per Sq. Ft.

Topography 2-6% Slope

Depth to Water Table 10'+

Rock or other impervious formations None observed.

_____ Basement with Plumbing _____ Basement without Plumbing ___✓___ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 720 Linear Ft. 240 +

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by Mike Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 2-1-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

**CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.**

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold