DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Craig & Kathryn Campbell — APPLICANT:
ADDRESS: 323 Sharon School Rd Statesville — APPLICATION DATE: 10 21 99 — DATE EVALUATED: 11.1.99
PROPOSED FACILITY: 3 Bdrm DW — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: 1.33
LOCATION OF SITE: I40 W Exit Sharon School (6) W Ke Dr on Right - Property on Left before gate Lot 29 Seizea Acres — PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 3-5%	0-8	SAB+ C-CL	FR					PS 3
		8-48	SAB C	FR 5% SCXF					
2	L 5-8%	0-48	SAB C	FR					PS .5
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	✓	✓
System Type(s)		
Site LTAR	.3	.5

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY:
OTHER(S) PRESENT: Owner