IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hugh Henline DATE 2-28-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-40 - To Sharon School Rd - T.R. - T.R. on 1501 - T.L. on 1654 T.L. 1655 - Last House on L. S. R. No. _____

SUBDIVISION NAME Sharon Colony LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20,000 sq ft +


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Slope to front of lot Low

Depth to Water Table _____

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from House and Carport should be diverted away from Tank & lines. Mr Henline is Purchasing lot next door, where part of drainline is. but final deed has not been drawn at this time.

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 2-28-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold