DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Joel Massey APPLICANT: Joel Massey
ADDRESS: 12272 Foxhound Lane Orlando APPLICATION DATE: ___ DATE EVALUATED: 3/3/04
PROPOSED FACILITY: 2BM/conv PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: 3.55
LOCATION OF SITE: ___ PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	7% Linear	0-6	SCL SBK	FR SS NP SE					PS .25
		6-48	C WEAK FI	PR BRK SP SE/P					
2	7% Linear	0-7	SCL SBK FI	SS SP SE/P		960			PS .25
		7-48	C WEAK FI	SP SE/P					
3	7% Linear	0-8	SCL SBK FR	SS NP SE/P		320 / 240			PS .25
		8-48	C WEAK FI	SP SE/P					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity, Conv	Gravity, Conv
Site LTAR	.25	.25

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: ___