~~1949~~ 13702 Charles Corn 41594

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR FLOYD & NORMA CORN DATE 11-14-91. PERMIT NO. 8G-3-A-18

PHONE: Business _____ Home _____

LOCATION I-40 W-Tf. on Sharon School Rd. go approx. one mile on left. Enter) dev. - 2nd lot on R. S. R. No. _____

SUBDIVISION NAME SHARON RIDGE DEV. LOT NO. 18. SECTION OR BLOCK NO. _____


House ( ) Mobile Home (4) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (4)
Auto. Dishwasher Yes ( ) No (4)
Auto. Wash. Machine Yes (4) No ( )
Site Suitable Yes (4) No ( )
Lot Area Ample.

Character & Porosity of Soil Prov. Suitable.
Percolation Rate 50 Lin. Ft.
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing 4 No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 728 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (4)

Installed by Keith Speece.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Norma J. Corn

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Do not drive or park over S.T. system.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 11-14-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold