IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 83375 PIN# 3793104463 DATE 12-10-99

OWNER OR CONTRACTOR Tim Perry PHONE: Business 871 8353 Home

ADDRESS 316 Sharon School Rd Sta. N.C.

LOCATION I-40 W TL Sharon School on left past mock mill Rd

SUBDIVISION BLOCK / SECTION LOT LOT AREA Acres SITE CLASS PS DESIGN FLOW 240 L.T.A.R. 133

Septic Tank: 1000 Gallons; STB 312 Date 11 6 99
Pump Tank: Gallons; PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 720 Linear Feet 240
No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: Conv. Gravity
Repair System Description: " "
Maintenance Agreement Required: ☐ Yes ☑ No

☐ House/Mod Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 2 No. Bathrooms 2 No. Employees

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☑ Public ☐ Community

Comments/Conditions:

Existing Mobile Home

INITIAL SITE SKETCH

Sharon School Rd

Auction House

Comments/Conditions:

AS BUILT SKETCH

Drive

Disp boxes

Repair area

As Shown

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit - not to exceed sixty months.

Signed: Tim P. date Installed by: Rhett Tucker

Improvement Permit by: R. C. Moore date 12-10-99 Operation Permit by: Joe Potter date 12-29-99

Authorization to Construct by: R. C. Moore date 12-10-99 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK