Everette Hoke
& Bldr.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rev. Elmer Strelowe DATE 5/31/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-40 To Sharon School Rd. T.R. Then T.R. on #1501 House on Rt. S. R. No. _____

SUBDIVISION NAME Sharon Colony LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 100 X 280

Character & Porosity of Soil Prof Suitable
Percolation Rate _____
Topography Slight Slope to back Low
Depth to Water Table _____
Rock or other impervious formations [redacted] Some rock along sidewall but None in bottom



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2 as shown
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Harlen Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6/1/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold