Jerry Hager Bldr.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ned Fox DATE 2-28-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-40 To Sharon School Rd T.R. T.R. on Rd 1501 T.L. on # 1654 T.L. on # 1655. Last House on R. S. R. No. _____

SUBDIVISION NAME Sharon Colony LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 Acre +

Character & Porosity of Soil Red Clay
Percolation Rate No Perk Test
Topography Slope to back of lot
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 252
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Robert Hope
Gene Fox

IMPROVEMENTS PERMIT BY E. G. Stevenson

COMMENTS: House under Construction Prior to Sept 1, 1973
All surface water from down spouts and yard should be diverted away from lines. Also Water from field above lines.

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 2-28-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold