IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 148353 PIN# 3793-38-6013

OWNER OR APPLICANT Clayton Homes DATE 5 March 08

ADDRESS 2026 Northside Drive Statesville, N.C. PHONE: Business 704-873-2547 Home

LOCATION Island Ford Rd. Turn into Goble - Lot on Rt.

SUBDIVISION BLOCK / SECTION LOT LOT AREA SITE CLASS. PS DESIGN FLOW 360 gpd L.T.A.R. 0.3 g/ft²/d

Septic Tank: 1000 Gallons; STB 560 Date 12-7-07

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet E 1200 Linear Feet 300

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: 25% Reduction

Repair System Description: 25% Reduction

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☑ Individual ☐ Public ☐ Community

☐ Gravity ☐ Pressure ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Follow Contour / Adhere to all setbacks.

Comments/Conditions: Filter installed

INITIAL SITE SKETCH

Please see Attached Layout

AS BUILT SKETCH

Installed as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 3-6-08

Improvement Permit by: R.S. date 5 March 08

Authorization to Construct by: R.S. date 5 March 08

Installed by: Jimmy Abee

Operation Permit by: R.S. date 16 April 08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK


3793-38-1831
569
240
284
3793-48-0429
GOBLE RD
3793-37-1778
860
286
850
75
171
3793-38-6013
283
3793-47-8589
880
890
870
3793-37-6814
229
295
840
1 inch equals 60 feet