IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 157489 PIN # 3793-44-7572 DATE 5 August 09

OWNER or APPLICANT Kimberly Mathis PHONE: Business 704-451-3398 Home: 704-508-1260

OWNER or APPLICANT ADDRESS 2581 PennGate Dr. Sherrills Ford, N.C.

LOCATION / DIRECTIONS Hwy 40 W TL Sharon School Rd. TL Mock Mill TR Titelist - TR Big Bethel TR Ping Ct. on Left.

SUBDIVISION Augusta Green BLOCK / SECTION 2 LOT # 28 LOT AREA DESIGN FLOW 360 g/d L.T.A.R. 0.3 g/ft²/d

2

Septic Tank 1000g Gallons: STB 954 Date 10-2-09

Pump Tank Gallons: P T Date 10-5-09

Pump Make Model Serial #

Nitrification Field No Fields 2 No Lines 6 Linear Feet 384

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☑ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: 25% Reduction

Repair System Description: 50% Reduction - LPP

Maintenance Agreement Required ☐ YES ☑ NO

☑ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 3

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☑ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☑ Public ☐ Community

Comments / Conditions: Basement plumbing only in small sub field.

Comments / Conditions: poly lock filter. both tanks

INITIAL SITE SKETCH

* Please see attached site sketch.

AS BUILT SKETCH

Installed as drawn on attached site sketch.

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☑ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☑ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Kim Bell Date 8/5/09

Improvement Permit by: [signature], R.S. Date 5 August 09

Authorization to Construct by: [signature], R.S. Date 5 August 09

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Blackburn & Sons

Operation Permit by: [signature], R.S. Date: 4 December 09

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant


3793-44-7749
230
157
3793-44-9857
110
3793-44-8612
113
27
3793-44-9682
295
3793-35-7451
244
80
110
185
103
28
277
BIG BERTHA DR
PB 48-73
140
PING CT
110
3793-44-7461
3793-54-0368
114
29
307
209
3793-32-7846
3793-44-7362
1 inch = 50 feet